

कार्यालय सहायक यंत्री लोक स्वास्थ्य यांत्रिकी उपखण्ड
बालाघाट

क्रमांक.....70...../लेब./लो.स्वा.यां./उपखण्ड,

बालाघाट दिनांक 19/08 2026

प्रति,


प्रिंसिपल,
सरदार पटेल इंटरनेशनल स्कूल बालाघाट,
जिला बालाघाट (म0प्र0)।

विषय:- जल परीक्षण रिपोर्ट देने बाबद्।

—00—

उपरोक्त विषयांतर्गत लेख है, कि आपके द्वारा भेजे गये जल नमूनों का परीक्षण कर रिपोर्ट पत्र के साथ संलग्न कर आपकी ओर प्रेषित है।

सहपत्र:- जल परीक्षण रिपोर्ट की सूची।


सहायक यंत्री
लोक स्वास्थ्य यांत्रिकी उपखण्ड
बालाघाट

WATER ANALYSIS LABORATORY (T.M.)
P.H.E. DIVISION LAB BALAGHAT, Disst. BALAGHAT

11.00AM

(1) SAMPLE RECEIVED ON DATE 15.05.2026

(2) DATE OF ANALYSIS 18.05.2026

S.No.	Characterist	Units	Requirement of Human Body (Desirable limit)	Cause of Rejection (Permissible Limit) In absence of Alternate Source	Sardar Patel International School Balaghat
1	Turbidity	N.T.U.	1.0	5.0	1.5
2	Color	Pletiniam, Cobald, Schel	5	15	5
3	P.H. Value	PH Scale	6.5 to 8.5	No Relaxation	7.1
4	Test of odour	-	Agreeable	Disgreeable	Agreeable
5	Chloride	PPM	250	1000	60
6	Conduivity	—,,—	Milimos	Micromos	224.6
7	Total Dissolved solids	—,,—	500	2000	120.8
8	Total Alkalinity	—,,—	200	600	165
9	Total Hardness	—,,—	200	600	210
10	Calcium Hardness	—,,—	75	200	42.90
11	Magnesium Hardness	—,,—	30	100	24.00
12	Sulphate	—,,—	200	400	28.25
13	Iron	—,,—	1	1.0	0.1
14	Fluoride	—,,—	1.0	1.5	0.1
15	Nitrate	—,,—	45	45	Nill
16	Fical Coliform	cfu/100ml	0	0.0	Nill


रसायनज्ञ
जल परीक्षण प्रयोगशाला
बालाघाट

PROFROMA FOR
SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE


No. 466

Dated:- 22/05/2026

It is certified that an inspection team headed by Assistant Engineer, Public Health Engineering Sub. Division Waraseoni inspected the **Sardar Patel International School, Balaghat** at **Sardar Patel Knowledge City, Waraseoni Road, Dongariya, Balaghat (M.P)** on 18/05/2026 and on the basis of Water Testing Report (Attached) bearing No 70 dated 19th May of 2026 (PHED Lab) Balaghat certified that the **Sardar Patel International School, Balaghat** at **Sardar Patel Knowledge City, Waraseoni Road, Dongariya, Balaghat (M.P)** has safe drinking water facility for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State / U. T. Govt.

This Certificate is valid till 21st May 2027

Signature with Seal: _____



Name of Officer: _____

V.K. Thakur
Assistant Engineer
P.H.E. Sub Division
Waraseoni

Designation: _____

Name & Address of Office / Department: _____

To

Sardar Patel International School,
Sardar Patel Knowledge City,
Waraseoni Road, Dongariya,
Balaghat (M.P)